



H.B. Fuller

A.B.N: 37 003 638 435 ACN: 003 638 435
H.B. Fuller Company Australia Pty Ltd
PO Box 4202, Dandenong Sth VIC 3175
PH: 613 9797 6222 FAX: 613 9797 6299

19th April 2016

RE: VOC of HB Fuller product Foster 32-19 Duct Sealant.

The VOC of the following product has been tested in accordance with the California South Coast air quality management rule 1168 and the results are as follows:

Product Name	VOC (g/L)
32-19 Duct Sealant	7.0

The details of the management rule including method of testing can be viewed at the following website:

www.arb.ca.gov/DRDB/SC/CURHTML/R1168.PDF

Yours sincerely,

Kris Bogos

Chemist
H.B. Fuller Company Australia Pty Ltd